

Sarasota Branch

Florida Registration No. 5950
 1724 Barber Road
 Sarasota, FL 34240
 Phone: 941-922-3526

Client:

Masterrock, LLC
 5802 Bee Ridge Road, Suite 101
 Sarasota, FL 34233

Project:

24-31-7207
 Masterrock Production Facility (QC Testing)
 3915 Goodrich Avenue
 Sarasota, FL 34234

Sample Details		
Date Sampled: 12/29/2024	Sampled By: Mark Ochs	Product: 57 Stone (1 1/2" to 3/8")
Sample Location: Stockpile at facility		Date Tested: 1/9/2025
Sample Description: Screened recycled concrete aggregate (RCA)		Tested By: Chris Oberhoff

Visual Description	Sieve Analysis (AASHTO T 27)	
Angularity: Not Determined Shape: Not Determined	Sieve Size 1-1/2 in.	% Passing As Tested 100
	1 in.	88
	1/2 in.	29
	No. 4	4
	No. 8	3
		% Passing Target¹
		100
		95 to 100
		25 to 60
		0 to 10
		0 to 5
Supplemental Testing Organic Content (%): Not Determined Carbonate Content (%): Not Determined	¹ Gradation requirements are based on FY 2024-25 FDOT Standard Specifications for Road and Bridge Construction, Section 901, Table 1.	

