



# UNIVERSAL ENGINEERING SCIENCES

Consultants In: Geotechnical Engineering  
Environmental Sciences • Construction Material Testing

1748 Independence Blvd., Suite B-1 • Sarasota, FL 34234 • (941) 358-7410

**Project Name:** Masterrock Yard  
**Client:** Masterrock, LLC  
**Project Number:** 1110.1000152.0000  
**Report Date:** 07/08/22  
**Report Number:** 661  
**Workorder Number:** 268307  
**Sample Identification:**  
**Description:** Brown sand  
**Location:** On-site Stockpile  
**Date Sampled:** 06/15/22  
**Source:** Screened Fill  
**Compaction Method:** Mechanical

**Standard Proctor:** \_\_\_\_\_  
**Modified Proctor:** AASHTO T-180


**Results:**

**Max. Dry Density:** 112 pcf  
**Optimum Water %:** 11 %

	%Passing #200 Sieve	Organic Content
	2.5%	2.4%

**Date Tested:** 06/20/22  
**Technician:** D.Childress

Results may exceed Project Specifications  
 Sampled by AASHTO T-2



Universal Engineering Sciences, Inc.

Reviewed By

Matthew Janney  
Lab Manager